



*Sedgwick County...  
working for you*

---

## Wichita-Sedgwick County Metropolitan Area Building and Construction Department

### **MABCD DIRECTIVE #13-E1 (ELECTRICAL DIRECTIVE)**

**ISSUE:** Residential Electrical Service Panels, Residential Wiring Conductors, MFH Wiring Conductors

**EFFECTIVE DATE:** 8/27/13

In one-, two- and multi-family dwellings a footing or stem wall that is located below the electrical service panel may extend not more than twelve (12) inches beyond the front of the panel if the panel is located in the garage, basement or the residential accessory structure.

All residential and their accessory building wiring conductors rated less than 90 amperes shall be copper.

All mobile or manufactured (MFH) homes and their accessory building wiring conductors rated 200 amperes or less shall be copper.

Thomas J. Stolz

Director – MABCD

8/27/13