



Wichita-Sedgwick County Metropolitan Area Building and Construction Department

MABCD DIRECTIVE #15-E11 (ELECTRICAL DIRECTIVE)

ISSUE: Permanent Meter Release for Mobile/Manufactured Homes

EFFECTIVE DATE: Immediately

Electrical service inspections (and subsequent release to the utility company for permanent electrical connection) must be performed by the Electrical section of the Metropolitan Area Building & Construction Department whenever the following occur.

- A mobile/manufactured home installed on new lots where electrical service has never been established.
- Any time a mobile/manufactured home has been removed from a lot and another home moved on the same lot.
- **E11.1** A Metropolitan Area Building & Construction Department licensed Electrical Contractor or Kansas licensed Mobile/Manufactured Home Installer must install the necessary electrical wiring, obtain the required electrical permit and request inspection.
- **E11.2** Before the electrical service will be released to the utility company for permanent connection, a Metropolitan Area Building & Construction Department inspector must inspect and confirm that the building in question is secured properly and meets the applicable requirements pertaining to blocking and tie-down.
- **E11.3** All wiring rated 200 ampere or less must be copper.

Tom Kerschen Chief Electrical/Elevator Inspector – MABCD 5/19/2015