



*Sedgwick County...  
working for you*

---

## Wichita-Sedgwick County Metropolitan Area Building and Construction Department

**MABCD DIRECTIVE #15-P6  
(PLUMBING DIRECTIVE)**

**ISSUE: Use of Polyethylene (PE) Water Service Piping**

**EFFECTIVE DATE: Immediately**

Polyethylene (P.E.) water service piping may extend inside a structure to the building master shut off valve; provided there are no branches taken off ahead of the building master shut off valve.

Beau Means  
Plumbing Chief – MABCD  
5/12/15